



FIRE BURGLARY INSTRUMENTS, INC.

50 Engineers Road, Hauppauge, New York 11788 • 516-582-6161

**ZONE EXPANSION MODULE
(3ZDM)
INSTALLATION INSTRUCTIONS
12-180-7001**

To install the 3ZDM module in the TS-12 fire panel:

1. Disconnect electrical power to the unit by switching off the system circuit breaker at the premises electrical panel.
2. Disconnect battery stand-by power at the Fire Alarm Panel.
3. Install nylon spacers supplied with 3ZDM as shown by Figure below.
4. Install 3ZDM board as shown by Figure below.
5. Install hold-down screws through 3ZDM board as shown by Figure below.
6. Wire 3ZDM board as required.
7. Reconnect stand-by battery.
8. Switch on the system circuit breaker at the premises electrical panel.
9. Perform a complete system check on the Fire Alarm System.

